

# IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Spring Valley MD No1

## Had the following Violations Identified During a Drinking Water Inspection

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Our water system recently violated a drinking water requirement. Although this situation is not an emergency, as our customers you have a right to know what happened, what you should do, and what we are doing to correct this situation.

A routine drinking water inspection conducted on May 18, 2026 by the state drinking water program identified the following violations that may pose a risk to public health.

Identified Violation	Required Language	Date Correction is Required	Steps We Are Taking
<b>M619: Management Supplier has not achieved the backflow prevention annual compliance ratio (T2).</b>	<b>Uncontrolled cross connections can lead to a back pressure or siphonage event that may allow contaminants or disease-causing organisms to enter the drinking water, which can cause diarrhea, nausea, cramps, and associated headaches.</b>	<b>10/14/26</b>	All backflow devices in the district are being scheduled for certification and records will be tracked and maintained.
<b>M613: Management Failure to Complete an Annual Backflow Report (T3).</b>	<b>N/A</b>	<b>5/18/2026</b>	A BPCCC program was provided for the year 2025, but there was no written BPCCC program for previous years. This violation was considered resolved on 5/18/26

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the inspection it was identified that we did not complete all monitoring/testing, were not monitoring correctly, or were monitoring at an inappropriate location. Therefore we cannot be sure of the drinking water quality during that time.

**What does this mean? What should I do?**

- There is nothing you need to do at this time. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

We anticipate resolving the problem by **10/14/2026**. For more information, please contact **AJ Beckman** at **Aj@publicalliancellc.com** or **720-213-6621**, or **7555 E. Hampden Ave., Suite 501, Denver, CO 80231**

*\*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.\**

This notice is being sent to you by: Spring Valley MD No1 - CO0120717  
Date distributed: **On or before July 16, 2026**